



Annual Drinking Water Report

2017 Consumer Confidence Report

2000 South Central Avenue
 PO Box 670
 Marshfield, WI 54449
 (715) 387-1195

<http://www.marshfieldutilities.org>

Marshfield Utilities is pleased to present to you this year's Annual Drinking Water Consumer Confidence Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source is 100% groundwater, obtained from 15 active producing wells located in six well fields in and around the City of Marshfield. Additional facilities include four booster pumping stations, five storage reservoirs, a water treatment facility, and approximately 144 miles of transmission and distribution water mains.

Marshfield Utilities has a source water protection plan (Well Head Protection Plan) available at our office that provides more information such as potential sources of contamination.

We are pleased to report that our drinking water is safe and meets federal and state requirements. If you have any questions about this report or your water utility, please contact John Richmond, Water Manager at (715) 898-2170.

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled City of Marshfield Utility Commission meetings, which are held on the second Monday of each month at 4:00 pm at the Marshfield Utilities office.

Marshfield Utilities routinely monitors for constituents in your drinking water according to Federal and State laws. The table on the reverse side shows the results of our monitoring for the period of January 1st to December 31st, 2017. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In the table on the reverse side you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Term	Definition
AL	Action Level: The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.
Level 1 Assessment	A level 1 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below that there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/ year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
TCR	Total Coliform Rule

Following is a list of contaminants that our water is tested for:

Microbiological Contaminants

1. Total Coliform Bacteria, 2. Fecal coliform and E.coli, 3. Turbidity

Radioactive Contaminants

4. Beta/photon emitters, 5. Alpha emitters, 6. Combined radium

Inorganic Contaminants

7. Antimony, 8. Arsenic, 9. Asbestos, 10. Barium, 11. Beryllium, 12. Cadmium, 13. Chromium, 14. Copper, 15. Cyanide, 16. Fluoride, 17. Lead, 18. Mercury (inorganic), 19. Nitrate (as Nitrogen), 20. Nitrite (as Nitrogen), 21. Selenium, 22. Thallium

Synthetic Organic Contaminants including Pesticides and Herbicides

23. 2,4-D, 24. 2,4,5-TP (Silvex), 25. Acrylamide, 26. Alachlor, 27. Atrazine, 28. Benzo(a)pyrene (PAH), 29. Carbofuran, 30. Chlordane, 31. Dalapon, 32. Di(2-ethylhexyl) adipate, 33. Di(2-ethylhexyl) phthalate, 34. Dibromochloropropane, 35. Dinoseb, 36. Diquat, 37. Dioxin [2,3,7,8-TCDD], 38. Endothall, 39. Endrin, 40. Epichlorohydrin, 41. Ethylene dibromide, 42. Glyphosate, 43. Heptachlor, 44. Heptachlor epoxide, 45. Hexachlorobenzene, 46. Hexachlorocyclo-pentadiene, 47. Lindane, 48. Methoxychlor, 49. Oxamyl [Vydate], 50. PCBs [Polychlorinated biphenyls], 51. Pentachlorophenol, 52. Picloram, 53. Simazine, 54. Toxaphene

Volatile Organic Contaminants

55. Benzene, 56. Carbon tetrachloride, 57. Chlorobenzene, 58. o-Dichlorobenzene, 59. p-Dichlorobenzene, 60. 1,2 Dichloroethane, 61. 1,1 - Dichloroethylene, 62. cis-1,2-ichloroethylene, 63. trans - 1,2 -Dichloroethylene, 64. Dichloromethane, 65. 1,2-Dichloropropane, 66. Ethylbenzene, 67. Styrene, 68. Tetrachloroethylene, 69. 1,2,4 -Trichlorobenzene, 70. 1,1,1 - Trichloroethane, 71. 1,1,2 - Trichloroethane, 72. Trichloroethylene, 73. TTHM [Total trihalomethanes], 74. Toluene, 75. Vinyl Chloride, 76. Xylenes

In addition to monitoring for the contaminants listed on the reverse of this page, we also monitor for Total Coliform Bacteria and for E. Coli Bacteria on a daily basis. This is done in our own laboratory which is state certified for the microbiological analysis of drinking water and is regulated by the State of Wisconsin.

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date	Violation	Typical Source of Contaminant
BARIUM (ppm)	2	2	0.096	0.061-0.096		NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM (ppb)	100	100	1	0-1		NO	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE (ppm)	4	4	0.7	0.6-0.7		NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)	100		3.0000	2.0000-3.0000		NO	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
NITRATE (NO3-N) (ppm)	10	10	4.30	2.00-4.30		NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
SODIUM (ppm)	n/a	n/a	37.00	27.00-37.00		NO	n/a

Inorganic Contaminants

Contaminant (units)	Action Level	MCLG	90 th Percentile Level Found	# of Results	Sample Date	Violation	Typical Source of Contaminant
COPPER (ppb)	AL=1.3	1.3	0.3200	0 of 30 results were above the action level.	6/23/2016	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppm)	AL=15	0	5.40	0 of 30 results were above the action level.	8/22/2016	NO	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts

Contaminant (units)	SITE	MCL	MCLG	Level Found	Range	Sample Date	Violation	Typical Source of Contaminant
HAA5 (ppb)	D-17	60	60	14	14		NO	By-product of drinking water chlorination
TTHM (ppb)	D-17	80	0	33.3	33.3		NO	By-product of drinking water chlorination
HAA5 (ppb)	D-19	60	60	10	10		NO	By-product of drinking water chlorination
TTHM (ppb)	D-19	80	0	39.4	39.4		NO	By-product of drinking water chlorination

Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date	Violation	Typical Source of Contaminant
RADIUM, (226 + 228) (pCi/l)	5	0	1.4	1.3-1.4		NO	Erosion of natural deposits

Volatile Organic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date	Violation	Typical Source of Contaminant
TRICHLOROETHYLENE (TCE) (ppb)	5	0	0.8	0.0-1.0		NO	Leaching from PVC pipes; Discharge from factories and dry cleaners

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. EPA requires us to participate in this monitoring.

Contaminant (units)	Level Found	Range	Sample Date
SULFATE (ppm)	23.00	18.00-23.00	
ISOPROPYLBENZENE (ppm)	0.38	0.38	3/12/14

Health Effects of Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Marshfield Utilities is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or <http://www.epa.gov/safewater/lead>.

We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water is SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or are man made. Those substances can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system.

The cost of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office at (715) 387-1195 if you have questions. At Marshfield Utilities, we work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life, and our children's future.